

ATTACHMENT 2

Suggested Conditions for Consents WGN 990209 (01) (02) and (03)

Standard Conditions for All Consents

1. The location, design and implementation of all works shall be carried out in accordance with the application and associated plans and documents received by the Wellington Regional Council, on 20 April 1999.
2. In terms of Section 123 (c) of the Resource Management Act 1991, the period for which this consent is granted is limited to fifteen years from the date of granting.
3. The Wellington Regional Council may review any or all of the conditions of this consent by giving notice of its intention to do so under section 128 of the Resource Management Act 1991, at any time within six months of the first, fifth and tenth anniversaries of the date of commencement of this consent for any of the following purposes:
 - (a) To deal with any adverse effects on the environment that may arise from the exercise of this consent, and which are appropriate to deal with at a later stage.
 - (b) To review the adequacy of any plan prepared for this consent so as to incorporate into the consent any modifications to any plan which may be necessary to deal with any adverse effects on the environment arising from the management or operation of these works.
4. The consent holder may apply at any time under section 127 of the Resource Management Act 1991 for the change or cancellation of any consent condition, other than condition 2 relating to the term of this consent.
5. The consent holder shall pay all actual and reasonable costs associated with any review of conditions pursuant to conditions 3 and 4.
6. The works shall remain the responsibility of the consent holder, and shall be maintained to the satisfaction of the Manager, Consents Management, Wellington Regional Council. The consent holder shall contact the Manager, Consents Management, Wellington Regional Council, prior to undertaking any repair works.

Note: Maintenance works shall not include any works which change the scope or nature of the works authorised by condition 1, or may result in significant disturbance of the stream bed.

Schedule 2

Specific Conditions for Water Permits WGN 990209 (01) and (02)

7. The consent holder shall keep operational logs which identify change in the operating procedures and unusual events which may occur at the plant. These records shall be provided to the Wellington Regional Council on request.
8. The combined total rate of take from any or all intakes operated by the permit holder on the Wainui Stream (Smiths Creek) shall not exceed 18.8 L/s (as an instantaneous flow); or 1,625,000 L/day; 7 days a week; 52 weeks a year.
9. The permit holder shall measure daily instantaneous flow, and the total daily volume supplied to the treatment plant from the Wainui Stream. This flow information shall be supplied to the Manager, Consents Management, Wellington Regional Council, upon request.

Schedule 3

Specific Conditions for Land Use Consent WGN 990209 (03)

7. The Manager, Consents Management, Wellington Regional Council, shall be given a minimum of 48 hours notice prior to the exercise of this permit.
8. All reasonable steps shall be taken to separate construction activities from flowing water.
9. All practicable steps shall be taken to minimise sediment and turbidity in the stream, during the implementation, construction and operation of the works.

Reasons for Conditions

Conditions 1 - 6 for (WGN 990209 (01) and (02)) are standard conditions relating to the need for information provided by the applicant to be adhered to when carrying out works, and for the WRC to be informed of the commencement of activity. A standard review condition is also included for the benefit of both the applicant and the WRC. Condition 7 relates specifically to the maintenance of the works.

Conditions 7 – 9 for (WGN 990209 (01) and (02)) are specific to the water permits and relate to the need to record abstraction and operation information from the Wainui Stream, and specifies the maximum rate of abstraction.

Conditions 7 – 9 for (WGN 990209 (03)) relate to the land use consent and are designed to ensure that there will be no adverse effects to the water body from the construction of a new emergency intake structure.