

Summary

	Water Group Cumulative Savings in Energy Use		Cost for 31 Days
	31 Days	20 Days	
Operational Changes	22%	14%	\$24,000
Source of Water Change (river water instead of aquifer for Petone)	23%	15%	
Diesel substitution for electrical energy			
Waini-mata WTP	32%	20%	\$144,000
Waterloo WTP	47%	30%	
Te Marua WTP	53%	34%	
Te Marua Pumping Station	65%	42%	